

ok

## Annexure-C

### PROFORMA FOR SAFE DRINKING WATER AND SANITATION CONDITION CERTIFICATE

No.

Dated: 24/08/2024

It is certified that an inspection team headed by Mr. Deepan Shyam (Chemist) & Lalit kr. (S.A.)

(Name of Officers with designation) from DISTRICT LEVEL WATER ANALYSIS

LABORATORY, U.P. JAL NIGAM, (PHED/Municipality) Inspected the ST. FRANCIS SCHOOL,

KNOWLEDGE PARK V, INSTITUTIONAL AREA, GREATER NOIDA WEST - U.P. (Name &

Address of the school) on 21/08/2024 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no C/7267/6/2024 dated 22/08/2024 of DISTRICT

LEVEL WATER ANALYSIS LABORATORY, U.P. JAL NIGAM, GAUTAM BUDDH NAGAR

(PHED Lab) certified that the ST. FRANCIS SCHOOL, PLOT NO. 61 - B, KNOWLEDGE PARK V,


INSTITUTIONAL AREA, GREATER NOIDA WEST - U.P. (Name of school) has safe drinking

water facilities for the students and members of staff of the institution. The school also

maintains hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid from 23.08.2024 to 22.08.2025



Name : Mohammad Amir

Designation : Assistant Engineer

Name & Address of the Office/Department:

DISTRICT LEVEL WATER ANALYSIS

LABORATORY, U.P. JAL NIGAM,

GAUTAM BUDDH NAGAR, (U.P.)

Assistant Engineer  
Division Office  
U.P. Jal Nigam (Gramin)  
G.B. Nagar

To

The Principal  
ST. FRANCIS SCHOOL,  
PLOT NO. 61 - B,  
KNOWLEDGE PARK V,  
INSTITUTIONAL AREA,  
GREATER NOIDA WEST - U.P.  
(Name & Address of the Institution)



# TEST REPORT

District Level Water Analysis Laboratory

Uttar Pradesh Jal Nigam (Rural)

Address: Badalpur Water Supply Scheme, Near polytechnic college  
Village- Badalpur, District- Gautam Buddha Nagar- 203207



TC-12227

Report No:	C/7267/2024	Issue Date:	23/08/2024
Customer Details			
Office Name and Address	ST. FRANCIS SCHOOL 61-B, Knowledge Park V, Institutional Area Greater Noida		
Ref Letter No	ST. FRANCIS SCHOOL		
Basic details of sample			
District	G. B. NAGAR	Village/Town	Greater Noida West
Location	ST. FRANCIS SCHOOL 61-B, Knowledge Park V, Institutional Area Greater Noida		
Water Source	R O	Sample No.	C/24/08/7267/P
Quantity of Sample	1000 ml	Date of Collection	21-08-2024
Receiving Date	21-08-2024		
Sample Depositor	Mr. Ashish		
Analysis Start Date	22-08-2024	Analysis Completion Date:	23-08-2024

Technical Data of Analysis						
S. No.	Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Reference Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH temp.(26°)	-	6.89	6.5-8.5	No Reaction	IS 3025 (Part 11) :2022
2	Turbidity	NTU	0.61	1.00	5.00	IS 3025 (Part 10) : 2023
3	Total Dissolved Solids	mg/L	50	500	2000	IS 3025 (Part 16) : 2023
4	Chloride as Cl	mg/L	08	250	1000	IS 3025 (Part 32) :2019
5	Total Alkalinity as CaCO3	mg/L	36	200	600	IS 3025 (Part 23) :2023
6	Total Hardness as CaCO3	mg/L	16	200	600	IS 3025 (Part 21) : 2019
7	Sulphate as SO4	mg/L	BDL	200	400	APHA 24 <sup>th</sup> edition- 4500- SO4 <sup>2-</sup>
8	Nitrate as NO3	mg/L	2.88	45	No Reaction	APHA 24 <sup>th</sup> edition- 4500- NO3 <sup>-</sup>
9	Calcium as Ca	mg/L	BDL	75	200	IS 3025 (Part 40) : 2023
10	Magnesium as Mg	mg/L	BDL	30	100	IS 3025 (Part 46) :2023
11	Odour	Qualitative	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018
12	Color	HU	1.09	5	15	IS 3025 (Part 4) : 2021
13	Iron as Fe	mg/L	BDL	1.0	No Reaction	APHA 24 <sup>th</sup> edition- 3500- Fe B
14	Fluoride as F-	mg/L	BDL	1.0	1.5	APHA 24 <sup>th</sup> edition- 4500- F C

#### Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days from the date of issue of tests reports unless otherwise specified.
5. Laboratory not collected the sample.
6. BDL Means Below Detection Limit (Ca as ca Lower Limit is 5mg/L, Mg as mg Lower Limit is 5 mg/L, Sulphate Lower Limit is 1mg/L, Iron Lower Limit is 0.1 mg/L, Fluoride Lower Limit is 0.1mg/L)

Prepared By-

*Raden*  
(District Level Water Analysis Laboratory)

District Level Water Analysis Laboratory  
U.P. Jal Nigam (R), Gautam Buddha Nagar

Authorized Signatory

*Deepan Sharma*  
Deepan Sharma  
(Quality/Technical Manager)

End of the Report